

ORDINANCE NO. 705

*Chapter*

AN ORDINANCE AMENDING ORDINANCE NO. 4-1-3 OF THE MUNICIPAL CODE OF THE CITY OF PAYETTE, RELATING TO THE BUILDING CODE TO AMEND THE BUILDING CODE TO PROVIDE FOR ADDITIONAL ELECTRICAL WIRING REQUIREMENTS WITHIN THE CORPORATE LIMITS OF PAYETTE.

BE IT ORDAINED BY THE MAYOR AND COUNCIL OF THE CITY OF PAYETTE, IDAHO:

That Section 4-1-3 of the Municipal Code of the City of Payette be, and the same is hereby amended by adding an additional section designated (E) to read as follows:

(E) The following additional electrical wiring requirements shall apply within the corporate limits of the city:

1. All electrical wiring in commercial and industrial installations, in any zone, shall be in metal raceways.
2. All places of public assembly, including, but not limited to schools, churches, fraternal orders, hospitals, rest homes, sanitariums, exhibition or entertainment buildings, whether publicly or privately owned or operated, shall be wired in metal raceways, within corporate limits.
3. In dwelling type occupancies of more than two units or apartments, metal raceways shall be the wiring method.
4. Metal raceways shall include only--Rigid metal conduit, electrical metallic tubing, surface metal raceways or mineral insulated-metal sheathed cable, excepting that, when new services or feeders are installed underground or incased in concrete, rigid non-metallic conduit may be used.
5. Exception to the foregoing:  
Conductors operating at 30 volts, or less, may be installed by any method.

PASSED By the City Council of the City of Payette, Idaho, this 20 day of December, 1966.

APPROVED By the Mayor of the City of Payette, Idaho, this 20 day of December, 1966.

J. J. Josephson  
Mayor.

ATTEST: