

ORDINANCE NO. 8/25

AN ORDINANCE ADDING Section 3-3-23 to Chapter 3 of Title 3 of the Municipal Code prohibiting contamination sources near city wells:

Be It Ordained by the Mayor and Council of the City of Payette, Idaho that Chapter 3 of Title 3 of the Municipal Code of the City of Payette, be amended by adding the following section:

3-3-23: It shall be unlawful for any person to permit or allow the following contamination sources to exist within the following minimum distances from any City water supply or City water well: Building sewer - 50 feet; septic tank - 50 feet; disposal field - 100 feet; seepage pit - 100 feet; dry well - 50 feet; cesspool - 150 feet; livestock - 50 feet.

That this Ordinance shall be in full force and effect from and after the day of its publication in the Independent Enterprise, a newspaper of general circulation in Payette, Idaho.

PASSED AND APPROVED by the Mayor and Council this 15th day of August, 1977.

Wesley O. Roehr
Wesley O. Roehr, Mayor of the City of Payette, Idaho

ATTEST:

Barbara A. Millard
Barbara A. Millard, Clerk of the City of Payette, Idaho